

1	WBH	1	Lobby	DF - Left	6/20/2016	10:02:00 PM	6/21/2016	6:02:00 AM	8:00	ND	pbw / ict
2	WBH	1	Lobby	DF - Right	6/20/2016	10:04:00 PM	6/21/2016	6:04:00 AM	8:00	ND	pbw / ict
3	WBH	1	105	KF	6/20/2016	10:05:00 PM	6/21/2016	6:05:00 AM	8:00	0.0012	pbw / ict
4	WBL	1	Lobby	DF - Outside staff office	6/20/2016	10:10:00 PM	6/21/2016	6:10:00 AM	8:00	ND	pbw / ict
5	WBL	1	Lobby	DF - Bottle filling station	6/20/2016	10:12:00 PM	6/21/2016	6:12:00 AM	8:00	ND	pbw / ict
6	WBL	1	Commons	OF	6/20/2016	10:15:00 PM	6/21/2016	6:15:00 AM	8:00	ND	pbw / ict
7	WBL	1	DHS	OF - First floor	6/20/2016	10:18:00 PM	6/21/2016	6:18:00 AM	8:00	ND	pbw / ict
8	WBL	1	200	OF	6/20/2016	10:35:00 PM	6/21/2016	6:35:00 AM	8:00	0.0012	pbw / ict
9	WBL	1	209	OF	6/20/2016	10:37:00 PM	6/21/2016	6:37:00 AM	8:00	ND	pbw / ict
1	SLC	1	107	OF	6/30/2016	10:02:00 PM	7/1/2016	6:02:00 AM	8:00	0.0017	pbw / ict
2	SLC	1	280	DF	6/30/2016	10:06:00 PM	7/1/2016	6:06:00 AM	8:00	ND	pbw / ict
3	SLC	1	248	OF	6/30/2016	10:09:00 PM	7/1/2016	6:09:00 AM	8:00	0.0012	pbw / ict
1	SLC	2	216	OF - Office	6/30/2016	10:20:00 PM	7/1/2016	6:20:00 AM	8:00	0.0022	pbw / ict
2	SLC	2	215	OF - Office	6/30/2016	10:22:00 PM	7/1/2016	6:22:00 AM	8:00	ND	pbw / ict
3	SLC	2	214	OF - Office	6/30/2016	10:23:00 PM	7/1/2016	6:23:00 AM	8:00	ND	pbw / ict
4	SLC	2	212	OF - Classroom	6/30/2016	10:25:00 PM	7/1/2016	6:25:00 AM	8:00	ND	pbw / ict
5	SLC	2	208	OF - Office	6/30/2016	10:27:00 PM	7/1/2016	6:27:00 AM	8:00	0.0077	pbw / ict
6	SLC	2	230	OF - Office	6/30/2016	10:29:00 PM	7/1/2016	6:29:00 AM	8:00	ND	pbw / ict
7	SLC	2	299	DF - Hallway	6/30/2016	11:03:00 PM	7/1/2016	7:03:00 AM	8:00	0.0044	pbw / ict
8	SLC	2	222	OF - Conference room	6/30/2016	11:06:00 PM	7/1/2016	7:06:00 AM	8:00	ND	pbw / ict
9	SLC	2	202	OF - Workroom	6/30/2016	11:08:00 PM	7/1/2016	7:08:00 AM	8:00	ND	pbw / ict
10	SLC	2	223	DF - Hallway	6/30/2016	11:10:00 PM	7/1/2016	7:10:00 AM	8:00	ND	pbw / ict
11	SLC	2	173	OF - Office	6/30/2016	11:17:00 PM	7/1/2016	7:17:00 AM	8:00	0.0015	pbw / ict
12	SLC	2	177	OF - Storage	6/30/2016	11:21:00 PM	7/1/2016	7:21:00 AM	8:00	ND	pbw / ict
13	SLC	2	172	OF - Dining	6/30/2016	11:24:00 PM	7/1/2016	7:24:00 AM	8:00	0.0105	pbw / ict
14	SLC	2	168	DF - Hallway	6/30/2016	11:27:00 PM	7/1/2016	7:27:00 AM	8:00	ND	pbw / ict
15	SLC	2	176D	OF - Conference room	6/30/2016	11:32:00 PM	7/1/2016	7:32:00 AM	8:00	ND	pbw / ict
16	SLC	2	180	KF - Store	6/30/2016	11:36:00 PM	7/1/2016	7:36:00 AM	8:00	ND	pbw / ict
17	SLC	2	132	KF - Kitchen	6/30/2016	11:40:00 PM	7/1/2016	7:40:00 AM	8:00	0.0015	pbw / ict
18	SLC	2	132	KF - Kitchen, west end	6/30/2016	11:46:00 PM	7/1/2016	7:46:00 AM	8:00	0.0094	pbw / ict
19	SLC	2	199	KF - Food court, east end	6/30/2016	11:49:00 PM	7/1/2016	7:49:00 AM	8:00	0.0084	pbw / ict
20	SLC	2	178	OF - Work area	6/30/2016	11:52:00 PM	7/1/2016	7:52:00 AM	8:00	0.0012	pbw / ict
21	SLC	2	199	DF - Hallway	6/30/2016	12:03:00 AM	7/1/2016	8:03:00 AM	8:00	0.0565***	pbw / ict
1	SLC	3	135	DF	6/30/2016	9:43:00 PM	7/1/2016	5:43:00 AM	8:00	0.0059	pbw / ict

2	SLC	3	137	DF	6/30/2016	9:45:00 PM	7/1/2016	5:45:00 AM	8:00	0.0048	pbw / ict
3	SLC	3	810	DF	6/30/2016	9:48:00 PM	7/1/2016	5:48:00 AM	8:00	0.0040	pbw / ict
4	SLC	3	272	OF - Office	6/30/2016	9:52:00 PM	7/1/2016	5:52:00 AM	8:00	0.0016	pbw / ict
5	SLC	3	131	OF - Office	6/30/2016	9:55:00 PM	7/1/2016	5:55:00 AM	8:00	ND	pbw / ict
6	SLC	3	910	DF - Hallway	6/30/2016	9:57:00 PM	7/1/2016	5:57:00 AM	8:00	0.0084	pbw / ict
7	SLC	3	260	OF - Classroom	6/30/2016	9:59:00 PM	7/1/2016	5:59:00 AM	8:00	0.0085	pbw / ict
8	SLC	3	277	OF - Classroom	6/30/2016	10:00:00 PM	7/1/2016	6:00:00 AM	8:00	ND	pbw / ict
1	SLC	4	801	DF	7/19/2016	5:20:00 PM	7/20/2016	6:22:00 AM	13:02	ND	ict
2	SLC	4	125	OF right side	7/19/2016	5:22:00 PM	7/20/2016	6:23:00 AM	13:01	0.0034	ict
3	SLC	4	125	OF left side	7/19/2016	5:23:00 PM	7/20/2016	6:24:00 AM	13:01	0.0040	ict
4	SLC	4	820	DF Hallway outside autolab	7/19/2016	5:24:00 PM	7/20/2016	6:25:00 AM	13:01	ND	ict
5	SLC	4	130	OF left most faucet	7/19/2016	5:25:00 PM	7/20/2016	6:26:00 AM	13:01	0.0023	ict
6	SLC	4	810	OF break area	7/19/2016	5:26:00 PM	7/20/2016	6:27:00 AM	13:01	0.0011	ict
7	SLC	4	811	DF lobby	7/19/2016	5:28:00 PM	7/20/2016	6:28:00 AM	13:00	ND	ict
8	SLC	4	814	BF-WRR	7/19/2016	5:30:00 PM	7/20/2016	6:29:00 AM	12:59	0.0023	ict
9	SLC	4	128	OF break area	7/19/2016	5:31:00 PM	7/20/2016	6:30:00 AM	12:59	ND	ict
10	SLC	4	901	DF upstairs lobby	7/19/2016	5:33:00 PM	7/20/2016	6:32:00 AM	12:59	ND	ict
11	SLC	4	231	OF classroom	7/19/2016	5:34:00 PM	7/20/2016	6:33:00 AM	12:59	0.0044	ict
12	SLC	4	224	OF storage rm in classroom	7/19/2016	5:36:00 PM	7/20/2016	6:34:00 AM	12:58	0.0043	ict
1	SLC	5	103	DF S wall	7/19/2016	6:00:00 PM	7/1/2016	6:50:00 AM	12:50	0.0161***	ict
2	SLC	5	103	OF E wall w eyewash	7/19/2016	6:01:00 PM	7/1/2016	6:51:00 AM	12:50	0.0016	ict
3	SLC	5	101	OF S wall	7/19/2016	6:02:00 PM	7/1/2016	6:52:00 AM	12:50	0.0010	ict
4	SLC	5	106	BF MRR left faucet	7/19/2016	6:03:00 PM	7/1/2016	6:53:00 AM	12:50	0.0088	ict
5	SLC	5	269	DF lobby across from 249	7/19/2016	6:05:00 PM	7/1/2016	6:39:00 AM	12:34	0.015***	ict
6	SLC	5	264F	OF work area	7/19/2016	6:07:00 PM	7/1/2016	6:37:00 AM	12:30	0.0041	ict
1	SLC	6	111	OF work room	7/19/2016	6:10:00 PM	7/20/2016	6:47:00 AM	12:37	ND	ict
2	SLC	6	122	DF Hallway outside rm 105	7/19/2016	6:11:00 PM	7/20/2016	6:46:00 AM	12:35	ND	ict
3	SLC	6	124	DF WRR	7/19/2016	6:13:00 PM	7/20/2016	6:44:00 AM	12:31	ND	ict
4	SLC	6	123	OF concessions	7/19/2016	6:15:00 PM	7/20/2016	6:43:00 AM	12:28	ND	ict
5	SLC	6	204	BF WRR	7/19/2016	6:17:00 PM	7/20/2016	6:41:00 AM	12:24	ND	ict
1	SLC	7	110	DF east wall	7/19/2016	6:25:00 PM	7/20/2016	7:00:00 AM	12:35	ND	ict
2	SLC	7	100	DF east wall	7/19/2016	6:26:00 PM	7/20/2016	7:01:00 AM	12:35	0.0019	ict
3	SLC	7	116	DF south wall	7/19/2016	6:28:00 PM	7/20/2016	7:02:00 AM	12:34	ND	ict

4	SLC	7	102	OF concessions	7/19/2016	6:30:00 PM	7/20/2016	7:04:00 AM	12:34	ND	ict
5	SLC	7	134	BF MRR	7/19/2016	6:31:00 PM	7/20/2016	7:05:00 AM	12:34	ND	ict
1	SLC	8	103E	OF	7/20/2016	5:28:00 PM	7/21/2016	6:42:00 AM	13:14	ND	ict & jah
2	SLC	8	1099	DF	7/20/2016	5:31:00 PM	7/21/2016	6:43:00 AM	13:12	ND	ict & jah
3	SLC	8	1060	BF WRR	7/20/2016	5:33:00 PM	7/21/2016	6:44	13:11	0.0030	ict & jah
4	SLC	8	1063	KF	7/20/2016	5:35:00 PM	7/21/2016	6:45:00 AM	13:10	ND	ict & jah
5	SLC	8	113BB	OF	7/20/2016	5:37:00 PM	7/21/2016	6:47:00 AM	13:10	ND	ict & jah
6	SLC	8	120	OF classroom	7/20/2016	5:39:00 PM	7/21/2016	6:48:00 AM	13:09	0.0280***	ict & jah
7	SLC	8	118	OF classroom	7/20/2016	5:41:00 PM	7/21/2016	6:49:00 AM	13:08	0.0062	ict & jah
8	SLC	8	116	DF north wall	7/20/2016	5:43:00 PM	7/21/2016	6:50:00 AM	13:07	ND	ict & jah
9	SLC	8	229	DF north wall	7/20/2016	5:44:00 PM	7/21/2016	6:27:00 AM	12:43	0.0011	ict & jah
10	SLC	8	113Y	OF	7/20/2016	5:51:00 PM	7/21/2016	6:29:00 AM	12:38	ND	ict & jah
11	SLC	8	2099	DF smaller drinking fountain	7/20/2016	5:52:00 PM	7/21/2016	6:31:00 AM	12:39	ND	ict & jah
1	SLC	9	212	OF circulation area	7/20/2016	6:08:00 PM	7/21/2016	7:00:00 AM	12:52	ND	ict & jah
2	SLC	9	104C	OF	7/20/2016	6:11:00 PM	7/21/2016	7:01:00 AM	12:50	ND	ict & jah
3	SLC	9	124	OF	7/20/2016	6:13:00 PM	7/21/2016	7:02:00 AM	12:49	0.0018	ict & jah
4	SLC	9	136	OF	7/20/2016	6:16:00 PM	7/21/2016	7:03:00 AM	12:47	ND	ict & jah
5	SLC	9	802	DF north wall	7/20/2016	6:18:00 PM	7/21/2016	7:04:00 AM	12:46	ND	ict & jah
6	SLC	9	817	BF WRR	7/20/2016	6:19:00 PM	7/21/2016	7:05:00 AM	12:46	0.0010	ict & jah
1	SLC	14	123	KF	7/20/2016	5:59:00 PM	7/21/2016	6:38:00 AM	12:39	0.0030	ict & jah
2	SLC	14	110	BF WRR	7/20/2016	6:02:00 PM	7/21/2016	6:39:00 AM	12:37	0.0020	ict & jah
1	SLC	20	810	DF	7/20/2016	7:02:00 PM	7/21/2016	7:27:00 AM	12:25	ND	ict & jah
2	SLC	20	813	BF WRR	7/20/2016	7:03:00 PM	7/21/2016	7:28:00 AM	12:25	ND	ict & jah
3	SLC	20	911	DF	7/20/2016	6:59:00 PM	7/21/2016	7:29:00 AM	12:30	ND	ict & jah
4	SLC	20	203D	KF	7/20/2016	7:01:00 PM	7/21/2016	7:30:00 AM	12:29	ND	ict & jah
1	SLC	21	100	DF	7/20/2016	7:06:00 PM	7/21/2016	7:20:00 AM	12:14	ND	ict & jah
2	SLC	21	100	OF	7/20/2016	7:07:00 PM	7/21/2016	7:21:00 AM	12:14	0.0025	ict & jah
1	SLC	22	144	DF hallway east end	7/20/2016	6:53:00 PM	7/21/2016	7:08:00 AM	12:15	0.0011	ict & jah
2	SLC	22	130	OF breakroom	7/20/2016	6:52:00 PM	7/21/2016	7:09:00 AM	12:17	ND	ict & jah
3	SLC	22	150	BF WRR	7/20/2016	6:50:00 PM	7/21/2016	7:10:00 AM	12:20	ND	ict & jah
4	SLC	22	105	OF breakroom	7/20/2016	6:48:00 PM	7/21/2016	7:11:00 AM	12:23	0.0016	ict & jah

5	SLC	22	112	OF classroom	7/20/2016	6:47:00 PM	7/21/2016	7:12:00 AM	12:25	0.0012	ict & jah
1	SLC	33	103	OF shop	7/20/2016	5:38:00 PM	7/21/2016	6:00:00 AM	12:22	0.0014	ict & jah
2	SLC	33	802	BF WRR	7/20/2016	5:37:00 PM	7/21/2016	6:01:00 AM	12:24	0.0072	ict & jah
1	SLC	34	107	DF hallway	7/20/2016	5:32:00 PM	7/21/2016	5:55:00 AM	12:23	ND	ict & jah
2	SLC	34	119	BF WRR	7/20/2016	5:33:00 PM	7/21/2016	5:56 AM	12:23	ND	ict & jah
3	SLC	34	108	KF baker sink	7/20/2016	5:34:00 PM	7/21/2016	5:57:00 AM	12:23	0.0014	ict & jah
4	SLC	34	108	KF prep sink	7/20/2016	5:34:00 PM	7/21/2016	5:59:00 AM	12:25	ND	ict & jah
1	SLC	36	120	BF WRR	7/20/2016	5:40:00 PM	7/21/2016	6:02:00 AM	12:22	ND	ict & jah
1	SLC	37	136	BF WRR	7/20/2016	5:42:00 PM	7/21/2016	6:03:00 AM	12:21	ND	ict & jah
2	SLC	37	137	OF break area	7/20/2016	5:43:00 PM	7/21/2016	6:04:00 AM	12:21	ND	ict & jah
1	SLC	38	115	BF WRR	7/20/2016	5:45:00 PM	7/21/2016	6:05:00 AM	12:20	ND	ict & jah
2	SLC	38	135	KF break area	7/20/2016	5:46:00 PM	7/21/2016	6:06:00 AM	12:20	ND	ict & jah
3	SLC	38	135	DF hallway	7/20/2016	5:47:00 PM	7/21/2016	6:07:00 AM	12:20	0.0019	ict & jah
1	SLC	40	108	OF break room	7/21/2016	6:20:00 PM	7/22/2016	6:10:00 AM	11:50	0.0012	ict & jah
2	SLC	40	210	OF mothers room	7/21/2016	6:22:00 PM	7/22/16	6:11 AM	11:49	0.0032	ict & jah
3	SLC	40	907	DF hallway	7/21/2016	6:23:00 PM	7/22/16	6:12:00 AM	11:49	ND	ict & jah
4	SLC	40	213	OF work room	7/21/2016	6:23:00 PM	7/22/2016	6:13:00 AM	11:50	ND	ict & jah
1	SLC	41	107	DF Hallway	7/21/16	6:26:00 PM	7/22/2016	6:14:00 AM	11:48	ND	ict & jah
2	SLC	41	109	OF locker room	7/21/2016	6:27:00 PM	7/22/2016	6:15:00 AM	11:48	0.0066	ict & jah
3	SLC	41	100	OF shop	7/21/2016	6:28:00 PM	7/22/2016	6:16:00 AM	11:48	ND	ict & jah
1	SLC	43	112	OF auto shop	7/21/2016	6:30:00 PM	7/22/2016	6:17:00 AM	11:47	0.0013	ict & jah
2	SLC	43	108	OF recycling shop	7/21/2016	6:31:00 PM	7/22/2016	6:18:00 AM	11:47	0.0039	ict & jah
3	SLC	43	105	DF hallway	7/21/2016	6:33:00 PM	7/22/2016	6:19:00 AM	11:46	ND	ict & jah
1	SLC	44	100	OF	7/25/2016	7:25:00 PM	7/26/2016	7:00:00 AM	11:35	0.0011	ict & jah
1	SLC	45	101	DF dugout eastside	7/25/2016	7:08:00 PM	7/26/2016	7:01:00 AM	11:53	0.0076	ict & jah
2	SLC	45	113	DF dugout westside	7/25/2016	7:09:00 PM	7/26/2016	7:03:00 AM	11:54	ND	ict & jah

1	SLC	48	255	OF sink prep area	7/25/2016	6:20:00 PM	7/26/2016	6:32:00 AM	12:12	0.0017	ict & jah
2	SLC	48	252	DF lobby	7/25/2016	6:21:00 PM	7/26/2016	6:33:00 AM	12:12	0.0010	ict & jah
3	SLC	48	101	DF lobby	7/25/2016	6:22:00 PM	7/26/2016	6:34:00 AM	12:12	ND	ict & jah
4	SLC	48	102	BF WRR	7/25/2016	6:23:00 PM	7/26/2016	6:35:00 AM	12:12	ND	ict & jah
1	SLC	49	802	BF WRR	7/13/2016	7:00:00 PM	7/14/2016	6:43:00 AM	11:43	0.0041	ict & jah
1.1	SLC	49	802	BF WRR	10/13/2016	6:00:00 AM	10/13/2016	6:37 AM	0:37	ND	ict & jah
2	SLC	49	107	KF	7/13/2016	7:01:00 PM	7/14/2016	6:45:00 AM	11:44	0.0277***	ict & jah
2.1	SLC	49	107	KF	9/20/2016	8:00:00 PM	9/21/2016	7:16:00 AM	11:16	0.0033	ict & jah
3	SLC	49	800	DF lobby	7/13/2016	7:02:00 PM	7/14/2016	6:42:00 AM	11:40	0.0025	ict & jah
3.1	SLC	49	800	DF lobby	9/20/2016	8:05:00 PM	9/21/2016	7:15 AM	11:10	ND	ict & jah

4	SLC	49	803	BF MRR	7/13/2016	7:03:00 PM	7/14/2016	6:50:00 AM	11:47	0.0054	ict & jah
4.1	SLC	49	803	BF MRR	10/13/2016	6:01:00 AM	10/13/2016	6:36:00 AM	0:35	ND	ict & jah
5	SLC	49	114A	OF	7/13/2016	7:04:00 PM	7/14/2016	6:52:00 AM	11:48	0.0699****	ict & jah
6	SLC	49	112A	OF	7/13/2016	7:05:00 PM	7/14/2016	6:55:00 AM	11:50	0.0051	ict & jah
7	SLC	49	202	OF office	7/13/2016	7:06:00 PM	7/14/2016	6:59:00 AM	11:53	0.087***	ict & jah
8	SLC	49	203	OF office	7/13/2016	7:07:00 PM	7/14/2016	7:01:00 AM	11:54	0.0599***	ict & jah
8.1	SLC	49	203	OF office	9/20/2016	8:04:00 PM	9/21/2016	7:18:00 AM	11:14	0.0090	ict & jah
9	SLC	49	205	OF office	7/13/2016	7:08:00 PM	7/14/2016	7:05:00 AM	11:57	0.143***	ict & jah
10	SLC	49	206	OF office	7/13/2016	7:09:00 PM	7/14/2016	7:07:00 AM	11:58	0.146***	ict & jah
11	SLC	49	207	OF office	7/13/2016	7:10:00 PM	7/14/2016	7:09:00 AM	11:59	0.337***	ict & jah
12	SLC	49	208	OF office	7/13/2016	7:11:00 PM	7/14/2016	7:10:00 AM	11:59	0.0623***	ict & jah
13	SLC	49	209	OF office	7/13/2016	7:12:00 PM	7/14/2016	7:12:00 AM	12:00	0.0534***	ict & jah
14	SLC	49	210	OF office	7/13/2016	7:13:00 PM	7/14/2016	7:16:00 AM	12:03	0.0994***	ict & jah
15	SLC	49	901	BF MRR	7/13/2016	7:14:00 PM	7/14/2016	7:19:00 AM	12:05	0.0698****	ict & jah
15.1	SLC	49	901	BF MRR	10/13/2016	6:15:00 AM	10/13/2016	6:38:00 AM	0:23	0.0010	ict & jah
16	SLC	49	215	OF office	7/13/2016	7:15:00 PM	7/14/2016	7:22:00 AM	12:07	0.0233***	ict & jah
17	SLC	49	216	OF office	7/13/2016	7:16:00 PM	7/14/2016	7:25:00 AM	12:09	0.185***	ict & jah
18	SLC	49	217	OF office	7/13/2016	7:17:00 PM	7/14/2016	7:27:00 AM	12:10	0.0832***	ict & jah
19	SLC	49	218	OF office	7/13/2016	7:18:00 PM	7/14/2016	7:30:00 AM	12:12	0.391***	ict & jah
20	SLC	49	902	BF WRR	7/13/2016	7:19:00 PM	7/14/2016	7:31:00 AM	12:12	0.0050	ict & jah
20.1	SLC	49	902	BF WRR	10/13/2016	6:03:00 PM	10/13/2016	6:39:00 AM	12:36	ND	ict & jah
21	SLC	49	226	OF office	7/13/2016	7:20:00 PM	7/14/2016	7:33:00 AM	12:13	0.0193***	ict & jah
21.1	SLC	49	226	OF office	9/20/2016	8:06 PM	9/21/2016	7:17:00 AM	11:11	0.0083	ict & jah
											ict & jah
1	SLC	53	101	DF lobby	7/25/2016	6:25:00 PM	7/26/2016	6:18:00 AM	11:53	ND	ict & jah

2	SLC	53	130D	KF sink kitchette	7/25/2016	6:26:00 PM	7/25/2016	6:19:00 AM	11:53	ND	ict & jah
3	SLC	53	102	BF WRR	7/25/2016	6:27:00 PM	7/26/2016	6:20:00 AM	11:53	ND	ict & jah
4	SLC	53	212	OF break area	7/25/2016	6:28:00 PM	7/26/2016	6:21:00 AM	11:53	ND	ict & jah
5	SLC	53	200	DF lobby	7/25/2016	6:29:00 PM	7/26/2016	6:22:00 AM	11:53	ND	ict & jah
1	SLC	60	106	OF break room	7/25/2016	7:05:00 PM	7/26/2016	7:02:00 AM	11:57	0.0011	ict & jah
2	SLC	60	102	BF WRR	7/25/2016	7:06:00 PM	7/26/2016	7:03:00 AM	11:57	0.0015	ict & jah
1	YVC	1	3099B	DF Hallway	7/26/16	10:22:00 PM	7/27/2016	8:30:00 AM	10:08	ND	ict & jah
2	YVC	1	300	OF Classroom	7/26/16	10:20:00 PM	7/27/2016	8:31:00 AM	10:11	ND	ict & jah
3	YVC	1	303	OF Classroom	7/26/16	10:21:00 PM	7/27/2016	8:32:00 AM	10:11	0.0076	ict & jah
4	YVC	1	312H	OF work room	7/26/16	10:24:00 PM	7/27/2016	8:33:00 AM	10:09	0.0018	ict & jah
5	YVC	1	2099	DF Hallway	7/26/16	10:26:00 PM	7/27/2016	8:34:00 AM	10:08	ND	ict & jah
6	YVC	1	1100	OF work room	7/26/16	10:29:00 PM	7/27/2016	8:35:00 AM	10:06	ND	ict & jah
7	YVC	1	1099C	DF Hallway	7/26/16	10:31:00 PM	7/27/2016	8:36:00 AM	10:05	ND	ict & jah
8	YVC	1	107	OF Mothers room	7/26/16	10:34:00 PM	7/27/2016	8:37:00 AM	10:03	0.0120	ict & jah
1	YVC	2	1054	OF mothers room	7/26/2016	9:45:00 PM	7/27/2016	8:42:00 AM	10:57	0.0084	ict & jah
2	YVC	2	1099G	DF Hallway	7/26/2016	9:46:00 PM	7/27/2016	8:41:00 AM	10:55	ND	ict & jah
3	YVC	2	125	OF classroom	7/26/2016	9:47:00 PM	7/27/2016	8:40:00 AM	10:53	0.0025	ict & jah
4	YVC	2	117	OF classroom	7/26/2016	9:48:00 PM	7/27/2016	8:39:00 AM	10:51	0.0035	ict & jah
5	YVC	2	1054	BF WRR	7/26/2016	9:50:00 PM	7/27/2016	8:38:00 AM	10:48	ND	ict & jah
1	YVC	4	1099C	BF Single RR	07/26/16	9:40:00 PM	7/27/2016	8:50:00 AM	11:10	0.0017	ict & jah
1	YVC	5	N/A	KF kitchen	7/26/2016	10:05:00 PM	7/27/2016	8:17:00 AM	10:12	0.0146	ict & jah
2	YVC	5	N/A	BF bathroom	7/26/2016	10:06:00 PM	7/27/2016	8:16:00 AM	10:10	0.0112	ict & jah
1	PKC	1	101	OF Staff Area	7/26/2016	7:28:00 PM	7/27/2016	7:32:00 AM	12:04	ND	ict & jah
2	PKC	1	151	DF Hallway	7/26/2016	7:29:00 PM	7/27/2016	7:33:00 AM	12:04	ND	ict & jah
3	PKC	1	108	DF classroom sink	7/26/2016	7:30:00 PM	7/27/2016	7:34:00 AM	12:04	ND	ict & jah
1	CCBI	1	412	KF kitchen	7/26/2016	7:10:00 PM	7/27/2016	6:40:00 AM	11:30	ND	ict & jah
2	CCBI	1	428	OF classroom	7/26/2016	7:11:00 PM	7/27/2016	6:41:00 AM	11:30	0.0035	ict & jah
3	CCBI	1	920	DF Hallway	7/26/2016	7:12:00 PM	7/27/2016	6:42:00 AM	11:30	ND	ict & jah
4	CCBI	1	301	KF break room	7/26/2016	7:13:00 PM	7/27/2016	6:43:00 AM	11:30	ND	ict & jah
5	CCBI	1	303	OF mothers room	7/26/2016	7:14:00 PM	7/27/2016	6:44:00 AM	11:30	0.0039	ict & jah

6	CCBI	1	825	DF Hallway	7/26/2016	7:15:00 PM	7/27/2016	6:45:00 AM	11:30	ND	ict & jah
7	CCBI	1	305N	BF singleRR	7/26/2016	7:16:00 PM	7/27/2016	6:46:00 AM	11:30	ND	ict & jah
8	CCBI	1	262	DF Hallway	7/26/2016	7:17:00 PM	7/27/2016	6:47:00 AM	11:30	ND	ict & jah
9	CCBI	1	172	BF WRR	7/26/2016	7:18:00 PM	7/27/2016	6:49:00 AM	11:31	0.0040	ict & jah
10	CCBI	1	162	DF Hallway	7/26/2016	7:21:00 PM	7/27/2016	6:50:00 AM	11:29	ND	ict & jah
11	CCBI	1	110	KF kitchen	7/26/2016	7:22:00 PM	7/27/2016	6:51:00 AM	11:29	0.0022	ict & jah
12	CCBI	1	114	KF kitchen	7/26/2016	7:24:00 PM	7/27/2016	6:52:00 AM	11:28	0.0061	ict & jah
13	CCBI	1	210K	OF staff area	7/26/2016	7:19:00 PM	7/27/2016	6:48:00 PM	23:29	0.0019	ict & jah

DF = Drinking Fountain KF = Kitchen Faucet OF = Other Faucet BF = Bathroom Faucet (Left most faucet, unless otherwise noted)

* EPA recommended Action Level is 0.015

** Standing Time accuracy is plus or minus 10 minutes.

*** Fixture was closed on the day the testing results were received. Fixture was or will be reopened following remediation of lead contamination source.

**** Fixture not intended for drinking water. Test results reported for troubleshooting only. Fixture to remain in service for non-drinking water purposes only.

Fixture has been permanently decommissioned.

Fixture has been re-tested

Re-test Result